



CERT

DIN-DVGW type examination certificate

DIN-DVGW-Baumusterprüfzertifikat

NG-5180CS0299

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of gas supply <i>Produkte der Gasversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	DEKOTEC GmbH Felderstraße 24, D-51371 Leverkusen
Distributor <i>Vertreiber</i>	DEKOTEC GmbH Felderstraße 24, D-51371 Leverkusen
Product Category <i>Produktart</i>	greasing and sealing materials: Protection tape against corrosion (5180)
Product Description <i>Produktbezeichnung</i>	Protection tape against corrosion
Model <i>Modell</i>	BUTYLEN-AS40 PLUS/-R20 HT with BUTYLEN-HT Primer
Test Reports <i>Prüfberichte</i>	laboratory control test: 21-01495-KP02- from 07.07.2022 (EBI) supplement test: 17/335/5180/4 from 08.01.2018 (EBI) type testing: 16/251/5180/7 from 13.06.2017 (EBI)
Test Basis <i>Prüfgrundlagen</i>	DIN EN 12068 (01.03.1999) DIN 30672 (01.12.2000)

Date of Expiry / File No. 13.06.2027 / 22-0364-GNV
Ablaufdatum / Aktenzeichen

13.10.2022 Fk A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle



DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Type	Technical Data	Remarks
<i>Typ</i>	<i>Technische Daten</i>	<i>Bemerkungen</i>
BUTYLEN-AS40 PLUS/-R20 HT with BUTYLEN-HT Primer	stress-class: C permanent operating temperature: up to +50 °C designation according to standard: coating DIN EN 12068-C 50 resp. DIN 30672-C 50	

Hints of Utilization / Remarks***Verwendungshinweise / Bemerkungen***

application: 4 (2+2) layers to be wrapped cold on top of primer coat "HT"