



CERT

DIN-DVGW type examination certificate

DIN-DVGW-Baumusterprüfzertifikat

NG-5181CS0304

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of gas supply <i>Produkte der Gasversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	DEKOTEC GmbH Felderstraße 24, D-51371 Leverkusen
Distributor <i>Vertreiber</i>	DEKOTEC GmbH Felderstraße 24, D-51371 Leverkusen
Product Category <i>Produktart</i>	greasing and sealing materials: Coatings for steel tubes (5181)
Product Description <i>Produktbezeichnung</i>	Heat shrinkable wraparound sleeve
Model <i>Modell</i>	DEKOTEC®-HTS70
Test Reports <i>Prüfberichte</i>	laboratory control test: 21-01021-KP02 from 06.10.2022 (EBI) laboratory control test: 16/119/5180/2 from 19.05.2017 (EBI)
Test Basis <i>Prüfgrundlagen</i>	DIN EN ISO 21809-3 (01.08.2016)

Date of Expiry / File No. 19.05.2027 / 22-0364-GNV
Ablaufdatum / Aktenzeichen

14.10.2022 Fk A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle



Deutsche
Akkreditierungsstelle
D-ZE-16028-01-05

DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
DEKOTEC®-HTS70	permanent operating temperature: up to +60 °C designation according to standard: coating DIN EN ISO 21809-3 type: 14-1	

Hints of Utilization / Remarks**Verwendungshinweise / Bemerkungen**

application: warm applied heat shrinkable sleeve